



# Certificate of Compliance

**Certificate:** 80208311 **Master Contract:** 301405  
**Project:** 80216259 **Date Issued:** 2024-06-26  
**Issued to:** Pegasus Solar Inc.  
506 W Ohio Avenue  
Richmond, California 94804  
United States  
**Attention:** Ian Lennox

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



**Issued by:** Michael Hoffnagle  
Michael Hoffnagle

## PRODUCTS

Class 5313 05 POWER SUPPLIES - PHOTOVOLTAICS - Photovoltaic Hazard Control  
Class 5313 85 POWER SUPPLIES - PHOTOVOLTAICS - Photovoltaic Hazard Control - US

**Racking systems for bonding and grounding of photovoltaic modules. The systems listed are designed to provide hazard controls for PV arrays mounted on roofs. The modules are bonded to the racking system and wire management to reduce hazards due to fire fighter interactions during various fault conditions. All components in the array shall be compliant with its given standards and rates shall meet requirements of installation and applicable standards per end use of system design of the array.**

Model(s)
PRS

The systems listed are designed to provide hazard controls for PV arrays mounted on roofs. The modules are bonded to the racking system and wire management to reduce hazards due to firefighter interactions during various fault conditions. All components in the array shall be compliant with its given standards and rates shall meet requirements of installation and applicable standards per end use of



**Certificate:** 80208311

**Master Contract:** 301405

**Project:** 80216259

**Date Issued:** 2024-06-26

---

system design of the array.

The grounding of the system is intended to comply with the latest edition of the National Electrical Code, including NEC 250 & 690 or in accordance with CSA C22.1, Safety Standard for Electrical Installations, Canadian Electrical Code, Part I. Local codes compliance is required, in addition to national codes.

### **APPLICABLE REQUIREMENTS**

ANSI/CAN/UL 3741 (First Edition) - UL Standard for Safety Photovoltaic Hazard Control



**Certificate:** 80208311

**Project:** 80216259

**Master Contract:** 301405

**Date Issued:** 2024-06-26

---

Notes:



## *Supplement to Certificate of Compliance*

**Certificate:** 80208311

**Master Contract:** 301405

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80216259	2024-06-26	UL 3741 to update Addendum documentation, assume review of document only and update attachment only.
80208311	2024-04-25	UL 3741 certification of Pegasus Rail System (PRS) systems; Includes Evaluation and Testing to UL 3741.