



# Certificate of Compliance

**Certificate:** 80191337

**Master Contract:** 300955

**Project:** 80191337

**Date Issued:** 2023-12-01

**Issued To:** Schletter Solar GmbH  
Alustraße 1  
Kirchdorf, Bavaria, 83527  
Germany

**Attention:** Martin Salazar

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*

**Issued by:** *Michael Hoffnagle*  
Michael Hoffnagle



## PRODUCTS

CLASS - C531385 - POWER SUPPLIES - PHOTOVOLTAICS- Photovoltaic Hazard Control -Certified to US Standards

Models: FixGrid Pro - Roof mount racking systems for bonding and grounding of photovoltaic modules.

The systems listed are designed to provide hazard controls for PV arrays mounted on roofs. The modules are bonded to the racking system and wire management to reduce hazard due to fire fighter interactions during various fault conditions. All components in array shall be compliant with its given standards and rates shall meet requirements of installation and applicable standards per end use of system design of array.



**Certificate:**  
**Project:** 80191337

**Master Contract:** 300955  
**Date Issued:** 2023-12-01

---

The grounding of the system is intended to comply with the latest edition of the National Electrical Code, to include NEC 250 & 690 or in accordance with CSA C22.1, Safety Standard for Electrical Installations, Canadian Electrical Code, Part I. Local codes compliance is required, in addition to national codes.

**Conditions of Acceptability:**

Installation is subject to acceptance of the local inspection authorities having jurisdiction. The certification of these products relates only to the methods of installation, bonding, and grounding as outlined in the Installation Manual for each product.

**APPLICABLE REQUIREMENTS**

ANSI/CAN/UL 3741 Ed. 1 - Photovoltaic Hazard Control  
December 8, 2020

**MARKINGS**

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US (indicating that products have been manufactured to the requirements of both Canadian and U.S. Standards) or with adjacent indicator 'US' for US only or without either indicator for Canada only.


The following markings appear on the plate by stamping:

- Submitter's logo and CSA Master Contract number "300955";
- Model designation;
- Maximum System Voltage;
- Manufacturing date;



**Certificate:**  
**Project:** 80191337

**Master Contract:** 300955  
**Date Issued:** 2023-12-01



Notes:



## *Supplement to Certificate of Compliance*

**Certificate:**

**Master Contract:** 300955

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
80191337	December 01, 2023	Transfer of all LOA project information for full certification to ANSI/CAN/UL 3741:2020 Ed.1